

Sandy Lake Borough

2020 Annual Water Quality Report

PWSID: 6430052

Este informe contiene informacion muy importante sobre su agua de beber. Traduzcalo o hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it, or speak to someone who understands it.)

We are pleased to present our Annual Water Quality Report. Sandy Lake Borough's Public Water Supply Identification Number (PWSID) is 6430052. This report includes water quality monitoring results for the calendar year 2020.

If you have any questions about this report or about your water quality, please contact Rod Paul at (724) 967-1503. You may also attend any of our regularly scheduled council meetings. Council meetings are held on the first Wednesday of the month at 7:00 P.M. in the Borough Building located at 3271 South Main Street, Sandy Lake, PA. You may also visit our website at <http://www.sandylakeborough.com>.

Sandy Lake Borough gets its water from three springs located on the Patton Farm property. A back-up well is also located at the farm. Sandy Lake Borough routinely monitors for contaminants in your drinking water according to federal and state laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2020. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

Detected Sample Results:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (distribution)	MRDL= 4	MRDLG = 4	1.22	0.71-1.22	ppm	11/2020	N	Water additive used to control microbes.
TTHM Trihalomethanes	80	NA	10.0	2.07-10.0	ppb	8/2020	N	By-product of drinking water chlorination
HAA5 Haloacetic Acids	60	NA	22.0	20.7-22.0	ppb	8/2020	N	By-product of drinking water disinfection
Nitrate	10	10	2.55	NA	ppm	7/2020	N	Runoff from fertilizer use.

Entry Point Disinfectant Residual:							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.40	0.64	0.64-3.8	ppm	7/2020	N	Water additive used to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead (2019)	15	0	12.9	ppb	0 of 10	N	Corrosion of household plumbing.
Copper (2019)	1.3	1.3	0.27	ppm	0 of 10	N	Corrosion of household plumbing.

Information about lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sandy Lake Borough is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCLs are set at very stringent levels. A person would have to drink 2 liters of water for a lifetime to have a one-in-a-million chance of having the identified health effect described for many regulated contaminants.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Minimum Residual Disinfectant Level - The minimum level of residual disinfectant required at the entry point to the distribution system.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

PWSID: Public water supply identification number

ppm = parts per million, or milligrams per liter (mg/L). One ppm corresponds to one minute in 2 years, or a single penny in \$10,000.

ppb = parts per billion, or micrograms per liter (µg/L). One ppb corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

< = less than

> = greater than

N/A = not applicable

Violations: In 2020 there were a few samples that were reported to the DEP late. These samples included the entry point and distribution system chlorine residuals in April. This incurred a record keeping violation under the Safe Drinking Water Act. There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater run-off and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater run-off and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).