

2025 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 6430052

NAME: Sandy Lake Borough

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact **Keystone Water Systems at (724) 588-2652**. Our water sources consist of 1 well and 3 springs located North of town off Patton Rd.

A Source Water Assessment of our sources was completed in 1993 by the PA Department of Environmental Protection (PADEP). The Assessment has found that our source is potentially most susceptible to road deicing materials, accidental spills along roads and leaks in underground storage tanks. Overall, our source has little risk of significant contamination. Summary reports of the Assessment will be available on the PADEP website at www.depweb.state.pa.us (Keyword: "source water"). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PADEP Meadville Regional Office, Records Management Unit at (814) 332-6899.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor some contaminants less than once per year because the concentration of these contaminants does not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS: *Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

Thank you for allowing us to continue providing your family with clean, quality water this year.

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range Of Detections	Units	Sample Date	Violation Y/N	Sources Of Contamination
Chlorine	4	4	1.42	0.61 - 1.42	ppm	12/2025	N	Water additive used to control microbes.
Arsenic	10	0	0.175	0.175	ppb	02/11/25	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.0189	0.0189	ppm	02/11/25	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Selenium	50	50	0.338	0.338	ppb	02/11/25	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Antimony	6	6	0.057	0.057	ppb	02/11/25	N	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
HALOACETIC ACIDS (HAA5)	60	n/a	3.28	2.46 – 3.28	ppb	08/14/25	N	By-product of drinking water chlorination
TRIHALOMETHANES (TTHM)	80	n/a	10.0	6.74 - 10.0	ppb	08/14/25	N	By-product of drinking water chlorination
Nitrates	10	10	3.63	3.17 - 3.63	ppm	03/06/25	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.40	0.46	0.46 - 2.89	ppm	07/27/25	N	Water additive used to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead (2025)	15	0	4.45	ppb	0 out of 10	N	Corrosion of household plumbing.
Copper (2025)	1.3	1.3	0.265	ppm	0 out of 10	N	Corrosion of household plumbing.

VIOLATIONS: There were no violations reported in 2025.

OTHER INFORMATION: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Sandy Lake Borough** is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Sandy Lake Boro has prepared a service line inventory that includes the type of material contained in each service line of our distribution system. This information can be accessed by contacting our Operator's office at (724) 588-2652.

EDUCATIONAL INFORMATION: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can

pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).